

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: Apr - June (Q2) 2023

Required Sample Frequency: 10/quarter

Location	Date	Cl2	Cond	Temp	pH	Alk	yes/no	< Has sample met the minimum water quality parameters?										
118	13-Apr	1.75	71	8.4	8.40	n/a	yes											
69	7-Jun	0.76	100	17.3	7.92	n/a	yes											
40	16-May	1.68	75	14.1	8.62	n/a	yes											
72	4-Apr	1.80	68	9.6	8.80	n/a	yes											
65	20-Apr	1.59	69	8.9	8.86	n/a	yes											
31	20-Apr	1.84	66	9.3	8.91	n/a	yes											
21	1-May	0.76	107	12.5	7.97	n/a	yes											
3	7-Jun	1.69	69	14.8	9.09	n/a	yes											
45	1-May	1.45	76	12.4	8.91	n/a	yes											
82	2-May	1.75	64	11.8	8.73	n/a	yes											
									<table border="1"> <tr> <td colspan="2">Minimum Water Quality Parameters as set by:</td> </tr> <tr> <td>pH</td> <td>7.40</td> </tr> <tr> <td>Alk</td> <td></td> </tr> <tr> <td>PO4</td> <td></td> </tr> <tr> <td>Other</td> <td></td> </tr> </table>	Minimum Water Quality Parameters as set by:		pH	7.40	Alk		PO4		Other
Minimum Water Quality Parameters as set by:																		
pH	7.40																	
Alk																		
PO4																		
Other																		

total number of excursions during this monitoring period = **0**

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 6.09.23