

### Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

**PWS Name/ID:** Tualatin Valley Water District/4100665

**Sample Period:** July - Sept (Q3)

**Required Sample Frequency:** 10/quarter

Location	Date	Cl2	Cond	Temp	pH	Alk	yes/no	< Has sample met the minimum water quality parameters?										
118	18-Sep	1.09	124	18.4	8.48	n/a	yes											
69	3-Jul	0.44	89	17.7	7.98	n/a	yes											
40	1-Aug	2.08	72	17.6	8.65	n/a	yes											
72	3-Jul	0.99	82	17.1	8.28	n/a	yes											
65	1-Aug	1.81	73	17.3	8.96	n/a	yes											
31	13-Sep	1.92	130	18.7	8.42	n/a	yes											
21	25-Jul	1.07	99	17.0	8.28	n/a	yes											
3	12-Sep	1.58	128	18.8	8.78	n/a	yes											
45	15-Aug	1.21	81	21.1	8.66	n/a	yes											
82	26-Sep	1.85	132	19.4	8.24	n/a	yes											
									<table border="1"> <tr> <td colspan="2">Minimum Water Quality Parameters as set by:</td> </tr> <tr> <td>pH</td> <td><b>7.40</b></td> </tr> <tr> <td>Alk</td> <td></td> </tr> <tr> <td>PO4</td> <td></td> </tr> <tr> <td>Other</td> <td></td> </tr> </table>	Minimum Water Quality Parameters as set by:		pH	<b>7.40</b>	Alk		PO4		Other
Minimum Water Quality Parameters as set by:																		
pH	<b>7.40</b>																	
Alk																		
PO4																		
Other																		

total number of excursions during this monitoring period = **0**

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

Print Name: William Richmond  
 Signature: *William Richmond*  
 Date: 10.05.2023