

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: Oct - Dec (Q4)

Required Sample Frequency: 10/quarter

Location	Date	Cl2	Cond	Temp	pH	Alk	yes/no	< Has sample met the minimum water quality parameters?										
118	23-Oct	0.81	134	17.2	8.26	n/a	yes											
69	7-Nov	1.18	130	15.6	8.54	n/a	yes											
40	10-Oct	1.79	128	18.7	8.67	n/a	yes											
72	6-Dec	1.34	79	14.0	8.46	n/a	yes											
65	26-Oct	1.17	133	14.8	8.52	n/a	yes											
31	8-Nov	1.79	128	14.4	8.41	n/a	yes											
21	27-Nov	0.91	134	11.2	8.04	n/a	yes											
3	12-Dec	0.51	89	11.8	8.62	n/a	yes											
45	1-Nov	0.99	135	15.9	8.13	n/a	yes											
82	5-Dec	1.76	75	11.5	8.82	n/a	yes											
									<table border="1"> <tr> <td colspan="2">Minimum Water Quality Parameters as set by:</td> </tr> <tr> <td>pH</td> <td>7.40</td> </tr> <tr> <td>Alk</td> <td></td> </tr> <tr> <td>PO4</td> <td></td> </tr> <tr> <td>Other</td> <td></td> </tr> </table>	Minimum Water Quality Parameters as set by:		pH	7.40	Alk		PO4		Other
Minimum Water Quality Parameters as set by:																		
pH	7.40																	
Alk																		
PO4																		
Other																		

total number of excursions during this monitoring period = **0**

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 1.09.24