Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: Jan - Mar (Q1)

Required Sample Frequency: 10/quarter

Location	Date	Cl2	Cond	Temp	pH	Alk	yes/no
118	22-Jan	1.26	98	7.60	7.96	n/a	yes
69	26-Feb	1.02	76	10.8	8.33	n/a	yes
40	10-Jan	1.44	78	9.4	8.54	n/a	yes
72	13-Mar	1.51	66	10.3	8.58	n/a	yes
65	6-Mar	1.52	68	7.4	8.25	n/a	yes
31	18-Mar	1.68	66	10.1	8.83	n/a	yes
21	13-Feb	1.24	116	9.00	7.94	n/a	yes
3	26-Feb	1.40	74	9.7	8.69	n/a	yes
45	23-Jan	0.98	104	9.7	7.82	n/a	yes
82	18-Mar	1.62	67	9.2	8.67	n/a	yes

< Has sample met the minimum water quality parameters?

Minimum Water Quality Parameters as set by:	
pH	**7.40**
Alk	
PO4	
Other	

tal number of excursions during this monitoring period = **0**

Send to *dwp.dmce@state.or.us* within 10 days after end of sampling period

Print Name: William Richmond

Signature: *William Richmond*

Date: 04.09.24