

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: Apr - June (Q2)

Required Sample Frequency: 10/quarter

Location	Date	Cl2	Cond	Temp	pH	Alk	yes/no	< Has sample met the minimum water quality parameters?	
118	10-Jun	1.78	75	14.80	8.81	n/a	yes		
69	22-Apr	1.78	69	13.2	8.65	n/a	yes		
40	3-Jun	1.84	70	13.9	8.85	n/a	yes		
72	3-Jun	1.81	70	14.2	8.83	n/a	yes		
65	8-May	1.62	70	12.1	8.81	n/a	yes		
31	4-Apr	1.75	65	10.4	8.55	n/a	yes		
21	13-May	1.00	118	13.60	8.05	n/a	yes		
3	4-Jun	1.52	71	14.3	8.79	n/a	yes		
45	20-May	1.38	82	15.8	8.51	n/a	yes		
82	4-Jun	1.62	67	13.4	8.81	n/a	yes		
								Minimum Water Quality Parameters as set by:	
								pH	7.40
								Alk	
								PO4	
								Other	
Number of excursions during this monitoring period =							0		

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: **William Richmond**
 Date: 06.15.24