Lead & Copper Rule Corrosion Control Report

WATER QUALITY MONITORING PARAMETERS - DISTRIBUTION SYSTEM

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: July - Sept (Q3)

Required Sample Frequency: 10/quarter

Location	Date	Cl2	Cond	Temp	pH	Alk	yes/no
118	9-Jul	1.10	85	17.3	8.84	n/a	yes
69	3-Sep	1.89	78	20.6	8.76	n/a	yes
40	7-Aug	1.29	90	18.5	8.48	n/a	yes
72	9-Jul	1.18	84	17.7	8.61	n/a	yes
65	20-Aug	1.85	90	18.8	8.68	n/a	yes
31	11-Sep	2.00	163	19.1	8.75	n/a	yes
21	1-Jul	1.12	104	16.1	8.11	n/a	yes
3	13-Aug	2.11	81	19.1	8.54	n/a	yes
45	18-Sep	0.17	113	21.3	8.28	n/a	yes
82	5-Aug	1.96	73	18.4	8.66	n/a	yes

< Has sample met the minimum water quality parameters?

Minimum Water Quality Parameters as set by:	
pH	**7.40**
Alk	
PO4	
Other	

Number of excursions during this monitoring period = **0**

Send to *dwp.dmce@state.or.us* within 10 days after end of sampling period

Print Name: William Richmond

Signature: *William Richmond*

Date: 10.10.24