

Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: May 2021

Frequency: Bi-weekly at EP while operating. Report each month even if not running.

Day	Time	Cl2	Cond	Temp	pH	Alk	yes/no
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12	ASR START UP BEGAN MAY 13, 2021						
13	10:10	1.04	121	11.2	7.82	n/a	yes
14							
15							
16							
17							
18							
19							
20	10:30	1.10	118	10.8	7.78	n/a	yes
21							
22							
23							
24							
25							
26							
27	11:16	1.34	116	9.2	7.74	n/a	yes
28							
29							
30							
31							
Total number of excursions for the month =							0

< Have pH minimums been met for this day?

Total excursions during previous five months: **0**
(Over 9 excursions in 6 months is a violation. EP and Dist excursions are cumulative)

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.4
Alk	n/a
PO4	n/a
Other	

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 06.10.21