

## Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

**PWS Name/ID:** Tualatin Valley Water District/4100665

Sample Period: June 2021

**Frequency:** Bi-weekly at EP while operating. Report each month even if not running.

Day	Time	Cl2	Cond	Temp	pH	Alk	yes/no		
1								< Have pH minimums been met for this day?	
2									
3	9:50	1.46	118	9.6	7.71	n/a	yes		
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16	10:00	0.51	138	10.8	7.70	n/a	yes		
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28	11:37	0.74	143	10.2	7.63	n/a	yes		
29									
30									
31									
Total number of excursions for the month =								0	Total excursions during previous five months: <b>0</b> (Over 9 excursions in 6 months is a violation. EP and Dist excursions are cumulative)
								For OHA use only:	
								Minimum Water Quality Parameters as set by OHA:	
						pH	7.4		
						Alk	n/a		
						PO4	n/a		
						Other			

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

Print Name: William Richmond  
 Signature: *William Richmond*  
 Date: 07.07.2021