

## Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

**PWS Name/ID:** Tualatin Valley Water District/4100665

Sample Period: July 2021

**Frequency:** Bi-weekly at EP while operating. Report each month even if not running.

Day	Time	Cl2	Cond	Temp	pH	Alk	pH Min met?	
1	14:27	0.23	74	18.8	7.82	n/a	yes	
2								
3	ASR Not running July 2 - July 13							
4	Turned back on July 14 in late afternoon							
5								
6								
7								
8								
9								
10								
11								
12								
13								
14	16:00	0.70	136	10.3	7.47	n/a	yes	
15								
16								
17								
18								
19								
20								
21								
22	12:05	0.89	161	10.4	7.52	n/a	yes	
23								
24								
25								
26								
27								
28	10:30	1.03	164	10.6	7.52	n/a	yes	
29								
30								
31								
Total number of excursions for the month =							0	Other

Total excursions during previous five months: **0**  
 (Over 9 excursions in 6 months is a violation. EP and Distribution excursions are cumulative)

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.4
Alk	n/a
PO4	n/a

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

Print Name: William Richmond  
 Signature: *William Richmond*  
 Date: 08.03.2021