


## Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

**PWS Name/ID:** Tualatin Valley Water District/4100665

Sample Period: August 2021 

**Frequency:** Bi-weekly at EP while operating. Report each month even if not running.

Day	Time	Cl2	Cond	Temp	pH	pH Min met?	
1	ASR Off						
2	ASR Off						
3	ASR Off						
4							
5							
6							
7							
8							
9	11:30	0.42	172	13.5	7.58	yes	
10							
11							
12							
13	11:40	0.64	180	11.3	7.51	yes	
14							
15							
16							
17							
18							
19							
20							
21							Total excursions during previous five months: <b>0</b>
22							(Over 9 excursions in 6 months is a violation. EP and Distribution excursions are cumulative)
23							
24							
25							
26							For OHA use only:
27	11:23	0.81	188	14.3	7.82	yes	Minimum Water Quality
28							Parameters as set by OHA:
29							pH
							7.4
30							Alk
							n/a
31							PO4
							n/a
Total number of excursions for the month =						<b>0</b>	Other

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

Print Name: William Richmond  
 Signature: *William Richmond*  
 Date: 09.30.2021