

## Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

**PWS Name/ID:** Tualatin Valley Water District/4100665

Sample Period: October 2021

**Frequency:** Bi-weekly at EP while operating. Report each month even if not running.

Day	Time	Cl2	Cond	Temp	pH	pH Min met?
1	ASR Off					
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						

Total excursions during previous five months: **0**  
 (Over 9 excursions in 6 months is a violation. EP and Distribution excursions are cumulative)

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.4
Alk	n/a
PO4	n/a
Other	

Total number of excursions for the month = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

Print Name: William Richmond  
 Signature: *William Richmond*  
 Date: 11.03.2021