

Lead & Copper Rule - Corrosion Control Report for Entry Point

Location: ENTRY POINT C (GRABHORN ASR)

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: May 2022 **REVISED REPORT**

Frequency: Bi-weekly readings during recovery. Send (blank) report monthly even if not running.

Notes: Recharging well at 500 gpm through May. The well does not operate during recharge.

JWC water is sent directly down the well for storage and does not enter the distribution system.

WQ parameters provided only when well is in 'recovery' mode (running and sent to distribution system).

Day	Time	Cl2	Cond	Temp	pH	pH Min met?
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						

Total excursions during previous five months: **0**
(Over 9 excursions in 6 months is a violation. EP and Distribution excursions are cumulative)

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.4
Alk	n/a
PO4	n/a

Total number of excursions for the month = **0** Other

Name: William Richmond
Date: 12.15.2022