


Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: July 2022 

Frequency: Bi-weekly at EP while operating. Report each month even if not running.

Notes: Recovery began July 25, **shut down August 8**

Day	Time	Cl2	Cond	Temp	pH	pH Min met?	
1							
2	12:30	0.71	138	11.4	7.77	yes	
3							
4	12:48	0.74	133	11.2	7.86	yes	
5							
6							
7							
8	Well shut off until Sept. 6						
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26						For OHA use only:	
27						Minimum Water Quality	
28						Parameters as set by OHA:	
29						pH 7.4	
30						Alk n/a	
31						PO4 n/a	
Total number of excursions for the month =						0	Other

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Total excursions in previous 5 months: 0

< 9 excursions in 6 months = violation

Print Name: William Richmond

Signature: *William Richmond*

(EP and Dist. excursions are cumulative)

Date:

9.08.22