

Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

PWS Name/ID: Tualatin Valley Water District/4100665

Monitoring Period: October 2022

Frequency: Bi-weekly at EP while operating. Report each month even if not running.

Notes: ASR Off. Not recovering or recharging. Plan to begin recharge in mid-November

Day	Time	Cl2	Cond	Temp	pH	pH Min met?	
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
Total number of excursions for the month =						0	Other

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.4
Alk	n/a
PO4	n/a

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Total excursions in previous 5 months: 0

> 9 excursions in 6 months = violation

(EP and Dist. excursions are cumulative)

Print Name: William Richmond

Signature: *William Richmond*

Date: 11.09.22