

**Lead & Copper Rule Corrosion Control Report**

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

**PWS Name/ID:** Tualatin Valley Water District/4100665

**Sample Period:** April - June (Q2) 2021

**Required Sample Frequency:** 10/quarter

Location	Date	Time	Cl2	Cond	Temp	pH	Alk	yes/no	Has sample met the minimum water quality parameters?		
118	21-Jun	10:04	1.33	44	16.6	8.26	n/a	yes			
69	14-Apr	11:20	1.85	32	11.4	8.20	n/a	yes			
40	26-Apr	12:02	1.54	39	12.7	8.42	n/a	yes			
72	17-May	13:48	1.88	35	14.8	8.12	n/a	yes			
65	21-Jun	12:34	1.57	38	14.8	8.19	n/a	yes			
31	18-May	10:54	1.68	31	13.3	7.95	n/a	yes			
21	17-May	11:02	1.05	107	14.3	8.08	n/a	yes			
3	1-Jun	12:42	1.33	36	14.6	8.07	n/a	yes			
45	17-May	13:08	0.94	68	16	7.99	n/a	yes			
82	21-Jun	10:14	1.38	27	15.8	8.14	n/a	yes			
									Minimum Water Quality Parameters as set by:		
										pH	<b>7.40</b>
										Alk	
										PO4	
										Other	
Total number of excursions during this monitoring period =									<b>0</b>		

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

Print Name: William Richmond  
 Signature: *William Richmond*  
 Date: 07.07.2021