

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: July - Sept (Q3) 2021

Required Sample Frequency: 10/quarter

Location	Date	Time	Cl2	Cond	Temp	pH	Alk	yes/no
118	23-Aug	12:00	1.71	129	19.3	8.12	n/a	yes
69	2-Aug	11:21	1.02	61	18.2	7.98	n/a	yes
40	28-Sep	12:00	1.87	54	18.9	8.35	n/a	yes
72	21-Sep	10:18	1.74	44	18.9	8.00	n/a	yes
65	26-Jul	14:10	0.39	91	20.8	7.81	n/a	yes
31	16-Aug	14:26	1.94	115	18.8	8.27	n/a	yes
21	19-Jul	14:53	0.93	99	16.0	7.89	n/a	yes
3	8-Sep	12:50	1.65	44	18.6	8.04	n/a	yes
45	3-Aug	13:30	0.39	91	20.8	7.81	n/a	yes
82	24-Aug	11:05	1.87	119	18.5	8.23	n/a	yes

< Has sample met the minimum water quality parameters?

Minimum Water Quality Parameters as set by:	
pH	7.40
Alk	
PO4	
Other	

Total number of excursions during this monitoring period = **0**

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 09.30.2021