

**Lead & Copper Rule Corrosion Control Report**

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

**PWS Name/ID:** Tualatin Valley Water District/4100665

**Sample Period:** Jan - Mar (Q1) 2022

**Required Sample Frequency:** 10/quarter

Location	Date	Time	Cl2	Cond	Temp	pH	Alk	yes/no
118	24-Jan	10:36	0.69	37	9.8	8.50	n/a	yes
69	1-Feb	1:46	1.86	33	9.3	8.30	n/a	yes
40	1-Feb	1:55	1.77	36	9.0	8.62	n/a	yes
72	4-Jan	10:55	1.73	40	11.8	8.02	n/a	yes
65	4-Jan	12:36	1.45	37	8.9	7.93	n/a	yes
31	19-Jan	11:15	1.76	28	9.9	8.30	n/a	yes
21	18-Jan	10:09	1.29	41	10.4	8.31	n/a	yes
3	11-Jan	10:48	1.66	32	9.8	8.30	n/a	yes
45	1-Feb	10:39	0.54	62	9.6	8.08	n/a	yes
82	4-Jan	12:50	1.48	30	8	8.20	n/a	yes

< Has sample met the minimum water quality parameters?

Minimum Water Quality Parameters as set by:	
pH	<b>7.40</b>
Alk	
PO4	
Other	

Total number of excursions during this monitoring period = **0**

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

Print Name: William Richmond  
 Signature: *William Richmond*  
 Date: 2.04.22