

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: July - Sept (Q3) 2022

Required Sample Frequency: 10/quarter

Location	Date	Time	Cl2	Cond	Temp	pH	Alk	yes/no
118	26-Sep	13:20	0.23	95	18.10	8.14	n/a	yes
69	6-Sep	14:04	1.04	102	18.4	7.94	n/a	yes
40	13-Sep	13:22	0.33	94	18.6	8.13	n/a	yes
72	14-Sep	12:20	0.10	93	18.3	7.84	n/a	yes
65	28-Sep	10:53	1.48	74	18.2	8.76	n/a	yes
31	14-Sep	13:46	2.02	66	18.4	8.74	n/a	yes
21	8-Sep	11:58	0.95	98	16.9	8.15	n/a	yes
3	13-Sep	11:51	1.66	70	19.3	8.71	n/a	yes
45	6-Sep	2:58	1.39	79	21	8.55	n/a	yes
82	14-Sep	12:41	1.97	65	18.3	8.70	n/a	yes

< Has sample met the minimum water quality parameters?

Minimum Water Quality Parameters as set by:	
pH	7.40
Alk	
PO4	
Other	

Total number of excursions during this monitoring period = **0**

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 10.05.22