

Day	pH	Alk	Phos	Other	Y/N
1	8.05				Y
2	8.04				Y
3	8.06				Y
4	8.07				Y
5	8.06				Y
6	8.05				Y
7	8.04				Y
8	8.07				Y
9	8.06				Y
10	8.04				Y
11	8.00				Y
12	8.00				Y
13	7.98				Y
14	8.00				Y
15	7.98				Y
16	7.99				Y
17	7.98				Y
18	7.97				Y
19	7.97				Y
20	7.98				Y
21	7.99				Y
22	7.98				Y
23	7.98				Y
24	7.98				Y
25	8.00				Y
26	7.99				Y
27	7.94				Y
28	7.95				Y
29	7.99				Y
30	8.02				Y

<<Have minimums been met for this day?

County: Multnomah Agency: REGION 1

**ENTRY POINT**

**EP-C**

**PWS ID 4100668**

**ROCKWOOD PUD**

Sample period: JUNE / 2021  
 Month/Year

Number of excursions during this month: 0


*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.8

Print Name: JAY BREEM

Signature: 

Date & Phone#: 7/1/2021 503.674-4512

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0