



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

| Day | pH   | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1   | 8.0  |     |      |       | Y   |
| 2   | 8.0  |     |      |       | Y   |
| 3   | 7.9  |     |      |       | Y   |
| 4   | 7.9  |     |      |       | Y   |
| 5   | 7.9  |     |      |       | Y   |
| 6   | 7.9  |     |      |       | Y   |
| 7   | 7.9  |     |      |       | Y   |
| 8   | 7.9  |     |      |       | Y   |
| 9   | 7.9  |     |      |       | Y   |
| 10  | 7.9  |     |      |       | Y   |
| 11  | 7.9  |     |      |       | Y   |
| 12  | 7.9  |     |      |       | Y   |
| 13  | 7.9  |     |      |       | Y   |
| 14  | 7.9  |     |      |       | Y   |
| 15  | 7.9  |     |      |       | Y   |
| 16  | 7.9  |     |      |       | Y   |
| 17  | 7.9  |     |      |       | Y   |
| 18  | 7.9  |     |      |       | Y   |
| 19  | 7.87 |     |      |       | Y   |
| 20  | 7.9  |     |      |       | Y   |
| 21  | 7.9  |     |      |       | Y   |
| 22  | 7.93 |     |      |       | Y   |
| 23  | 7.9  |     |      |       | Y   |
| 24  | 7.9  |     |      |       | Y   |
| 25  | 7.9  |     |      |       | Y   |
| 26  | 7.9  |     |      |       | Y   |
| 27  | 7.9  |     |      |       | Y   |
| 28  | 7.9  |     |      |       | Y   |
| 29  | 7.9  |     |      |       | Y   |
| 30  | 7.9  |     |      |       | Y   |
| 31  | 7.9  |     |      |       | Y   |

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

County: Multnomah Agency: REGION 1

**ENTRY POINT**  
**EP-C**  
**PWS ID 4100668**  
**ROCKWOOD PUD**

Sample period: July / 2021  
Month/Year

Number of excursions during this month: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.8

Print Name: JAY BREEN  
Signature:   
Date & Phone#: 8/3/2021 503-674-4572

Send to DWP within 10 days after end of sampling period