

Day	pH	Alk	Phos	Other	Y/N
1	OFF				OFF
2	↓				↓
3					
4	✓				✓
5	8.37				Y
6	OFF				OFF
7					
8	↓				↓
9					
10	↓				↓
11	✓				✓
12	8.16				Y
13	8.14				Y
14	OFF				OFF
15					
16	↓				↓
17					
18	↓				↓
19					
20	↓				↓
21					
22	↓				↓
23					
24	↓				↓
25	✓				✓
26	8.5				Y
27	OFF				OFF
28	↓				↓
29					
30	↓				↓
31	↓				↓

<<Have minimums been met for this day?

County: Multnomah Agency: REGION 1

ENTRY POINT
EP-C
PWS ID 4100668
ROCKWOOD PUD

Sample period: JAN / 2022
 Month/Year

Number of excursions during this month: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.8

Print Name: JAY BREEN

Signature: 

Date & Phone#: 2/1/2022 503.674-4512

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0