



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	off				off
2	↓				↓
3	↓				↓
4	7.86				Y
5	off				off
6	↓				↓
7	↓				↓
8	↓				↓
9	↓				↓
10	↓				↓
11	8.06				Y
12	off				off
13	↓				↓
14	↓				↓
15	↓				↓
16	↓				↓
17	↓				↓
18	7.84				Y
19	off				off
20	↓				↓
21	↓				↓
22	↓				↓
23	↓				↓
24	↓				↓
25	7.84				Y
26	off				off
27	8.18				Y
28	off				off
29	↓				↓
30	↓				↓
31	off				off

<<Have minimums been met for this day?

County: Multnomah Agency: REGION 1

ENTRY POINT
EP-C
PWS ID 4100668
ROCKWOOD PUD

Sample period: May / 2022
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.8

Print Name: JAY BREEN
Signature: [Signature]
Date & Phone#: 6/2/2022 503.674-4512

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0