



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	OFF				OFF
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14	↓				↓
15	8.38				Y
16	OFF				OFF
17	↓				↓
18					
19	↓				↓
20	8.37				Y
21	8.43				Y
22	8.41				Y
23	8.40				Y
24	8.39				Y
25	8.39				Y
26	8.39				Y
27	8.41				Y
28	8.42				Y
29	8.42				Y
30	8.43				Y

(No = N = Excursion) Total N's ϕ

<<Have minimums been met for this day?

County: Multnomah Agency: REGION 1

**ENTRY POINT**

**EP-C**

**PWS ID 4100668**

**ROCKWOOD PUD**

Sample period: JUNE / 2022  
Month/Year

Number of excursions during this month: ϕ

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.8

Print Name: JAY BREEN

Signature:

Date & Phone#: 7/1/2022 503.674-4512

Send to DWP within 10 days after end of sampling period