



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.2				Y
2	8.2				
3	8.2				
4	8.2				
5	8.2				
6	8.2				
7	8.2				
8	8.2				
9	8.2				
10	8.2				
11	8.2				
12	8.1				
13	8.1				
14	8.1				
15	8.1				
16	8.1				
17	8.1				
18	8.1				
19	8.1				
20	8.1				
21	8.1				
22	8.1				
23	8.1				
24	8.1				
25	8.1				
26	8.1				
27	8.1				
28	8.1				
29	8.1				
30	8.1				✓

<<Have minimums been met for this day?

County: Multnomah Agency: REGION 1

**ENTRY POINT**  
**EP-C**  
**PWS ID 4100668**  
**ROCKWOOD PUD**

Sample period: SEP. / 2022  
 Month/Year

Number of excursions during this month: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.8

Print Name: JAY BREEN  
 Signature: [Signature]  
 Date & Phone#: 10/4/2022 503.674-4512

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0