



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.1				Y
2	8.1				Y
3	8.0				Y
4	8.1				Y
5	8.1				Y
6	8.1				Y
7	8.1				Y
8	8.0				Y
9	8.1				Y
10	8.0				Y
11	8.0				Y
12	8.0				Y
13	8.1				Y
14	8.1				↓
15	8.1				Y
16	—				—
17	8.0				Y
18	8.0				Y
19	—				—
20	—				—
21	8.0				Y
22	8.0				Y
23	—				—
24	—				—
25	—				—
26	8.0				Y
27	—				—
28	—				—
29	—				—
30	—				—
31	—				—

<<Have minimums been met for this day?

County: Multnomah Agency: REGION 1

**ENTRY POINT**

**EP-C**

**PWS ID 4100668**

**ROCKWOOD PUD**

Sample period: OCT / 2022  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.8

Print Name: JAY BREEN

Signature:

Date & Phone#: 11/4/2022 503.674-4512

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>