

Day	pH				Y/N
1	8.0				Y
2	8.1				Y
3	8.1				Y
4	8.1				Y
5	8.1				Y
6	OFF				OFF
7	OFF				OFF
8	8.0				Y
9	OFF				OFF
10	-				↓
11	-				↓
12	-				↓
13	-				↓
14	-				↓
15	-				↓
16	8.0				Y
17	OFF				OFF
18	-				↓
19	-				↓
20	-				↓
21	-				↓
22	8.2				Y
23	OFF				OFF
24	8.3				Y
25	8.1				Y
26	8.1				Y
27	8.1				Y
28	8.1				Y
29	8.1				Y
30	OFF				OFF
31	OFF				OFF
<b>(No = N = Excursion) Total N's</b>					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	6	6	8
---	---	---	---	---

**System Name:** Rockwood Water PUD

**Entry Point:** EP-C

**Sample Period:** DEC 2022  
*Month/Year*

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.8	
Alk		<i>(Alkalinity)</i>
PO4		<i>(Orthophosphate)</i>
Other		<i>(_____)</i>

**Print Name:** Jay Breen

**Signature:**

**Date:** 1/3/2023

Send to DWP within 10 days after end of sampling period