

Day	pH	Alk	Phos	Other	Y/N
1	OFF				OFF
2	OFF				OFF
3	8.1				Y
4	8.2				Y
5	OFF				OFF
6	↓				↓
7	↓				↓
8	↓				↓
9	↓				↓
10	↓				↓
11	8.1				Y
12	8.1				Y
13	OFF				OFF
14	↓				↓
15	↓				↓
16	↓				↓
17	↓				↓
18	↓				↓
19	↓				↓
20	↓				↓
21	↓				↓
22	↓				↓
23	↓				↓
24	↓				↓
25	↓				↓
26	8.2				Y
27	OFF				OFF
28	↓				↓
29	↓				↓
30	8.2				Y
31	8.2				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 0 0 6 6 8

**System Name:** Rockwood Water PUD

**Entry Point:** EP-C

**Sample Period:** JAN. / 2023  
Month/Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.8

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

**Print Name:** Jay M. Breen

**Signature:**

**Date:** 2/1/2023

Send to DWP within 10 days after end of sampling period