

Day	pH	Alk	Phos	Other	Y/N
1	8.17				Y
2	OFF				OFF
3	↓				↓
4	↓				↓
5	↓				↓
6	↓				↓
7	↓				↓
8	↓				↓
9	↓				↓
10	↓				↓
11	↓				↓
12	8.16				Y
13	OFF				OFF
14	↓				↓
15	↓				↓
16	↓				↓
17	↓				↓
18	8.09				Y
19	OFF				OFF
20	↓				↓
21	↓				↓
22	↓				↓
23	↓				↓
24	↓				↓
25	↓				↓
26	↓				↓
27	↓				↓
28	8.58				Y
29	8.65				Y
30	8.59				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	6	8
---	---	---	---	---

System Name: Rockwood Water PUD

Entry Point: EP-C

Sample Period: April 1 2023
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.8

Alk

--

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 (_____)

Print Name: Jay M. Breen

Signature: [Signature]

Date: 5/1/23

Send to DWP within 10 days after end of sampling period