

Day	pH	Alk	Phos	Other	Y/N
1	OFF				OFF
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	✓				✓
16	8.2				Y
17	8.2				
18	8.1				
19	8.0				
20	8.0				
21	8.0				
22	8.0				✓
23	OFF				OFF
24	8.0				Y
25	8.0				Y
26	8.0				Y
27	OFF				OFF
28	8.1				Y
29	OFF				OFF
30	OFF				OFF
31	8.1				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	6	8
---	---	---	---	---

System Name: Rockwood Water PUD

Entry Point: EP-C

Sample Period: JAN. / 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.8

Alk

--

 (Alkalinity)

PO4

--


 (Orthophosphate)

Other

--

 (_____)

Print Name: Jay M. Breen

Signature: 

Date: 2/6/2024

Send to DWP within 10 days after end of sampling period