

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	OFF				OFF
2	↓				↓
3	↓				↓
4	↓				↓
5	8.3				Y
6	OFF				OFF
7	↓				↓
8	↓				↓
9	↓				↓
10	↓				↓
11	↓				↓
12	8.2				Y
13	OFF				OFF
14	↓				↓
15	↓				↓
16	↓				↓
17	↓				↓
18	↓				↓
19	8.3				Y
20	OFF				OFF
21	↓				↓
22	↓				↓
23	↓				↓
24	↓				↓
25	↓				↓
26	8.3				Y
27	OFF				OFF
28	↓				↓
29	↓				↓
30	↓				↓
31	↓				↓
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 6 6 8

System Name: Rockwood Water PUD

Entry Point: EP-C

Sample Period: JAN. / 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.8
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Jay M. Breen

Signature: [Signature]

Date: 2/4/2025

Send to DWP within 10 days after end of
sampling period