

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	6	6	8
---	---	---	---	---

System Name: Rockwood Water PUD

Entry Point: EP-C

Sample Period: SEP. / 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.8	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Jay M. Breen

Signature: [Signature]

Date: 10/1/25

Send to DWP within 10 days after end of sampling period