

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.9				Y
4	OFF				OFF
5					
6					
7					
8					
9					↓
10	7.9				Y
11	7.9				Y
12	OFF				OFF
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					↓

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 0 0 6 6 8

System Name: Rockwood Water PUD

Entry Point: EP-C

Sample Period: OCT. / 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.8	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Jay M. Breen

Signature: Jay M. Breen

Date: 11-3-25

Send to DWP within 10 days after end of
sampling period