

# Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	other	Y/N
PH1	24217 SE OAK ST.	8.28	30			Y
PH2	235 <sup>TH</sup> DIVISION	8.61	30			Y
PH3	BELLA VISTA DISCHARGE	8.83	35			Y
PH4	19711 NE HARSEY ST.	8.81	35			Y
PH5	905 SE 210 <sup>TH</sup> AVE	8.54	30			X
PH6	1421 SE 208 <sup>TH</sup> AVE	8.68	25			Y
PH7	15650 SE ALDER ST.	8.57	30			Y
PH8	18828 NE DAVIS ST.	8.65	30			Y
PH9	1840 SE 142 <sup>ND</sup> AVE	8.53	30			Y
PH10	133 NE 133 <sup>RD</sup> AVE	8.56	30			Y

<Has sample met the minimums? **DISTRIBUTION**

PWS ID: 41

System Name: Rockwood Water PUD

Sample Period: 5-2023  
Month/Year

Sample Frequency: Every 6 mo

Distribution Samples required: 10

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH  (Alkalinity)

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other

Print Name: Jed Pacheco

Signature: [Signature]

Date: 5/24/2023

(N = No = Excursion) Total N's

Send to Drinking Water Program within 10 days after end of sampling period:  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350