



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.2	60			Y
6	7.2				Y
7	7.2				Y
8	7.2				Y
9	7.2				Y
10	7.2				Y
11	7.2				Y
12	7.2	60			Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.3	60			Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.3	60			Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.3	60			Y
31	7.2				Y

<<Have minimums been met for this day?

County: Curry Agency: REGI

**ENTRY POINT
EP-A**

**PWS ID 4100670
PORT ORFORD, CITY OF**

Sample period: July 2021
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
**Minimum Water Quality
Parameter(s) as set by State:**
pH 7.2

Print Name: Kurt Franceschine
Signature: Kurt Franceschine
Date: 7-31-21

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period