



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
-1	7.3				Y
2	7.2				Y
3	7.4				Y
4	7.2				Y
5	7.3				Y
6	7.3	44			Y
7	7.2				Y
8	7.2				Y
9		Plant	Off		
10		Plant	Off		
11	7.3				Y
12	7.3				Y
13	7.3	37			Y
14	7.2				Y
15	7.3				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.3	56			Y
21		Plant	Off		
22	7.2				Y
23	7.2				Y
24	7.3				Y
25	7.2				Y
26	7.3				Y
27		Plant	Off		
28	7.2				Y
29	7.2				Y
30	7.3	43			Y
31	7.3				Y

<<Have minimums been met for this day?

County: Curry    Agency: REGI

## ENTRY POINT

### EP-A

### PWS ID 4100670

### PORT ORFORD, CITY OF

Sample period: Dec. / 2022  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

(No = N = Excursion) Total N's 0

Print Name: Kurt Franceschine

Signature: *Kurt Franceschine*

Date: 1/2/2023

Send to DWP within 10 days after end of sampling period