



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3				Y
2	7.3				Y
3	7.3	46			Y
4	7.2				Y
5	7.2				Y
6	7.2				Y
7		Plant	Off		
8		Plant	Off		
9	7.2				Y
10	7.2	46			Y
11	7.2				Y
12		Plant	Off		
13		Plant	Off		
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.2	48			Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.3				Y
23	7.2				Y
24	7.2	42			Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.3				Y
31	7.2	46			Y

<<Have minimums been met for this day?  
Y

County: Curry Agency: REGI

**ENTRY POINT**

**EP-A**

**PWS ID 4100670**

**PORT ORFORD, CITY OF**

Sample period: Jan. / 2023  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Kurt Franceschine

Signature: *Kurt Franceschine*

Date: 2/1/2023

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period