



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5		Plant	Off		
6	7.2				Y
7	7.2	50			Y
8	7.2				Y
9	7.2				Y
10	7.3				Y
11	7.2				Y
12	7.2				Y
13	7.3				Y
14	7.2	50			Y
15	7.2				Y
16	7.2				Y
17	7.3				Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2	46			Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.3				Y
26		PLANT	OFF		
27		PLANT	OFF		
28		PLANT	OFF		
29					
30					
31					

<<Have minimums been met for this day?

County: Curry    Agency: REGI

## ENTRY POINT

### EP-A

### PWS ID 4100670

### PORT ORFORD, CITY OF

Sample period: Feb./2023  
Month/Year

Number of excursions during this month: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Kurt Franceschine  
 Signature: *Kurt Franceschine*  
 Date: 3/1/2023

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period