



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1		Plant Off			
2	7.4				Y
3	plant off				Y
4	7.3				Y
5	7.3	24			Y
6	Plant	Off			
7	Plant	Off			
8	7.3				Y
9	7.3				Y
10	7.2				Y
11	7.2				Y
12	7.2	36			Y
13	7.3				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.2				Y
19	PLANT OFF				
20	7.3				Y
21	7.2	36			Y
22	PLANT OFF				
23	7.2				Y
24	7.2				Y
25	PLANT OFF				
26	7.2	38			Y
27	PLANT OFF				Y
28	7.2				Y
29	PLANT OFF				
30	7.3				Y
31	7.2				Y

<<Have minimums been met for this day?

County: Curry Agency: REGI

ENTRY POINT

EP-A

PWS ID 4100670

PORT ORFORD, CITY OF

Sample period: DEC-2023
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date: 4 Jan 2024

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period