

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Plant	off			
2	7.2				Y
3	7.3	30			Y
4	7.3				Y
5	7.2				Y
6	Plant	off			
7	7.3				Y
8	7.2				Y
9	Plant	off			
10	7.2	38			Y
11	7.2				Y
12	7.2				Y
13	Plant	off			
14	7.2				Y
15	7.2				Y
16	7.3				Y
17	Plant	off			
18	7.3				Y
19	7.4				Y
20	7.3				Y
21	plant	off			
22	7.2				Y
23	7.3				Y
24	7.2				Y
25	7.2				Y
26	Plant	off			
27	Plant	off			
28	7.2				Y
29	Plant	off			
30	7.3	42			Y
31	Plant	off			
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: Water plant, 1635 Arizona St.

Sample Period: January 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

--

(Alkalinity)
 PO4

--

(Orthophosphate)
 Other

--

(_____)

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date: 1 February 2024

Send to DWP within 10 days after end of sampling period