

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	7.3				Y
4	7.2				Y
5		Plant	Off		
6	7.2	32			Y
7		Plant	Off		
8	7.2				Y
9	7.2				Y
10	7.3				Y
11	7.2				Y
12	7.2				Y
13	7.3	36			Y
14	7.3				Y
15		Plant	Off		
16	7.2				Y
17		Plant	Off		
18	7.2				Y
19	7.3				Y
20	7.2	32			Y
21	7.3				Y
22	7.2				Y
23	7.2				Y
24	7.3				Y
25	7.2				Y
26	7.3				Y
27	7.2	28			Y
28	7.3				Y
29		Plant	Off		
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City Of

Entry Point: Water plant, 1635 Arizona St.

Sample Period: February 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

--

(Alkalinity)
 PO4

--

(Orthophosphate)
 Other

--

(_____)

Print Name: David Terrusa

Signature: *IS/David Terrusa*

Date: 01 March 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
