

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1		Plant	Off		
2	7.3				Y
3		Plant	Off		
4	7.3				Y
5	7.3	30			Y
6	7.2				Y
7	7.2				Y
8	7.3				Y
9		Plant	Off		
10		Plant	Off		
11		Plant	Off		
12	7.3	23			Y
13	7.3				Y
14	7.3				Y
15	7.2				Y
16	7.3				Y
17	7.2				Y
18	7.3				Y
19	7.2	32			Y
20	7.3				Y
21	7.3				Y
22	7.3				Y
23		Plant	Off		
24	7.2				Y
25	7.2				Y
26	7.2	38			Y
27	7.3				Y
28		Plant	Off		
29	7.3				Y
30	7.3				Y
31	7.3				Y
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: Water plant, 1635 Arizona St.

Sample Period: March, 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

--

(Alkalinity)
 PO4

--

(Orthophosphate)
 Other

--

(_____)

Print Name: David R. Terrusa

Signature: /S/ David R Terrusa

Date: 06 Aprils 2024

Send to DWP within 10 days after end of sampling period