

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2		Plant	Off		
3	7.2				Y
4		Plant	Off		
5	7.2				Y
6	7.3				Y
7	7.3	33			Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.2				Y
14	7.2	45			Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.3				Y
20	7.3				Y
21	7.3	42			Y
22	7.3				Y
23	7.3				Y
24	7.2				Y
25	7.2				Y
26	7.3				Y
27	7.3	38			Y
28	7.3				Y
29	7.3				Y
30	7.2				Y
31	7.2				
					0

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: Water Plant 1635 Arizona St.

Sample Period: May, 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 Alk

--

(Alkalinity)
 PO4

--

(Orthophosphate)
 Other

--

(_____)

Print Name: David Terrusa

Signature: David Terrusa

Date: 6/5/2024

Send to DWP within 10 days after end of sampling period