

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2	44			Y
5	7.2				Y
6	7.2				Y
7	7.2				Y
8	7.2				Y
9	7.2				Y
10	7.2				Y
11	7.2	24			Y
12	7.3				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.3				Y
18	7.2	44			Y
19	7.2				Y
20	7.2				Y
21	7.3				Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30	7.2	34			Y
31					
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00670

System Name: Port Orford, City of

Entry Point: Water plant, 1635 Arizona St.

Sample Period: June 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: David Terrusa

Signature: /s/ David Terrusa

Date: 4 July 2024

Send to DWP within 10 days after end of sampling period