

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2	28			Y
3	7.2				Y
4	7.3				Y
5	7.2				Y
6	7.2				Y
7	7.2				Y
8	7.3				Y
9	7.2	26			Y
10	7.2				Y
11	7.2				Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2	24			Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2	28			Y
24	7.3				Y
25	7.3				Y
26	7.3				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.3	28			Y
31	7.2				Y
					0

(No = N = Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: Water Plant, 1635 Arizona

Sample Period: July, 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		<i>(Alkalinity)</i>
PO4		<i>(Orthophosphate)</i>
Other		<i>(_____)</i>

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date: 8/8/2024

Send to DWP within 10 days after end of sampling period