

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1	7.3	28			
2	7.3				
3	7.3				
4	7.2				
5	7.3				
6	7.2				
7	7.2				
8	7.2	22			
9	7.2				
10	7.3				
11	7.2				
12	7.2				
13	7.2				
14	7.3				
15	7.2	22			
16	7.3				
17	7.2				
18	7.3				
19	7.2				
20	7.2				
21		Plant	Off		
22	7.2	24			
23	7.2				
24	7.2				
25	7.2				
26	7.3				
27	7.2				
28	7.2				
29	7.2	28			
30	7.2				
31	7.2				
No = N	 = Exc	cursion) Tota	I N's -	0

<<Have minimums been met for this day? PWS I

ENTRY POINT

PWS ID: 41 0 0 6 7 0

System Name: Port Orford, City of

Entry Point: 1635 Arizona St.

Sample Period: October, 2024

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

		Vater Quality s as set by
рН	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: David Terrusa

Signature:/S/ David Terrusa

Date: 11/06/2024

Send to DWP within 10 days after end of

sampling period