

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1		PLANT	OFF		
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.3	26			Y
6	7.2				Y
7	7.2				Y
8	7.2				Y
9	7.3				Y
10	7.3				Y
11		PLANT	OFF		
12	7.3	32			Y
13	7.2				Y
14	7.3				Y
15	7.3				Y
16	7.2				Y
17		PLANT	OFF		
18	7.3				Y
19	7.2	28			Y
20		PLANT	OFF		
21	7.2				Y
22	7.2				
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.2	26			Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.2				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: PORT ORFORD, CITY OF

Entry Point: 1635 ARIZONA ST.

Sample Period: NOVEMBER 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 (_____)

Print Name: David Terrusa

Signature: /S/ DAVID TERRUSA

Date: 2 December 2024

Send to DWP within 10 days after end of sampling period