

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2	26			Y
5	7.2				Y
6	7.2				Y
7	7.2				Y
8	7.2				Y
9	7.2				Y
10	7.2	26			Y
11	7.2				Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.3				Y
17	7.3	28			Y
18		plant	off		
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.3				Y
23	7.2				Y
24	7.2	30			Y
25	7.3				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.2				Y
31	7.3	28			Y
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: 1635 ARIZONA ST.

Sample Period: 12/2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

--

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 ()

Print Name: David Terrusa

Signature: /s/ David Terrusa

Date: 6 Jan 2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's