

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2	32			Y
5	7.2				Y
6	7.2				Y
7	7.2				Y
8	7.2				Y
9	7.3				Y
10	7.3				Y
11	7.2	28			Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2	26			Y
19	plant	off			
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	plant	off			
24	plant	off			
25	7.3	28			Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 0 0 6 7 0

System Name: Port Orford, City of

Entry Point: 1635 Arizona St.

Sample Period: February 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other (_____)

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date: 3/5/25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's