

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	7.2				Y
4	7.2				Y
5	7.2				Y
6	7.3	26			Y
7	7.3				Y
8	7.4				Y
9	7.2				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.2	24			Y
14	7.2				Y
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.2				Y
19	7.2				Y
20	7.3	24			Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.2	26			Y
28	7.3				Y
29	7.3				Y
30	7.2				Y
31	7.3				Y
(No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: 1635 Arizona St.

Sample Period: May, 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<table border="1" style="display: inline-table;"><tr><td>7.2</td></tr></table>	7.2	
7.2			
Alk	<table border="1" style="display: inline-table;"><tr><td></td></tr></table>		(Alkalinity)
PO4	<table border="1" style="display: inline-table;"><tr><td></td></tr></table>		(Orthophosphate)
Other	<table border="1" style="display: inline-table;"><tr><td></td></tr></table>		(_____)

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date: 04 June 2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's