

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.3				Y
6	7.3	26			Y
7	7.3				Y
8	7.3				Y
9	7.2				Y
10	7.2				Y
11	7.3				Y
12	7.2	32			Y
13	7.2				Y
14	7.2				Y
15	7.3				Y
16	7.2				Y
17	7.2				Y
18	7.3				Y
19	7.2	31			Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.5				Y
25	7.3				Y
26	7.2	36			Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.3				Y
31	7.3				Y
					0

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	6	7	0
---	---	---	---	---

System Name: Port Orford, City of

Entry Point: 1635 Arizona St.

Sample Period: August 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date: 09/06/2025

Send to DWP within 10 days after end of sampling period